



5.2 P.F. setting


After setting the C/K value



Press the “Manual” key



Use the  or  buttons to change the selection. A P.F. of 0,95 is recommended.

By pressing the  button, the C/K and P.F. values which have been selected will be saved and the regulator works in “Automatic” condition.

ENGLISH