# Automatic Power Factor Correction equipment



**B50** series equipment are particularly suitable for three-phase networks with operating voltage equal to **400 Vac** (+/- 10%) with **medium harmonic distortion** in current. These equipment guarantee an accurate P.F.C., thanks to a multi-step design that effectively divides the power. In addition, on the G6E and G8E cabinet, all the capacitors banks are assembled on racks, easily removable from the front of the panel, for simple management and maintenance.

#### **PERFORMANCE DATA**

Rated voltage 415 Vac (others on request)

Rated frequency 50 Hz (60 Hz on request)

■ Insulation voltage 690 Vac

auxiliary voltage 400 Vac for G3E, G4E, G4RM¹

230 Vac for G4RM<sup>2</sup>, G6E, G8E

Overvoltage 1,1 Un (rated voltage)

Temperature range -5 / +40 °C

Impulse withstand 6 kV (G3E, G4E);

8 kV (G4RM, G6E, G8E)

<sup>1</sup>up to 200 kvar. <sup>2</sup>over 200 kvar. Auxiliary voltage is supplied by a proper transformer.

# HARMONIC CONTENT (in the absence of resonance)

THD(I)max. = 35% on the network

THD(Ic)max. = 80% on the capacitors

#### **TECHNICAL DATA**

Enclosures Made of sheet steel, protected against corrosion by phosphating and epoxy powder coating. RAL 7035 colour (others on

request). Degree of protection: external panel IP 31, with the exception of type G3E and G4E with IP30 (others on request);

internal panel IP 20 at the input of power cables (IP 20 with open doors on request).

**Installation** Indoor installation, in a well ventilated position away from heat sources.

**Ventilation** Natural for powers up to 200 kvar; Forced for powers over 200 kvar.

**Switch isolator** Tri-polar under-load type with door lock.

Wiring The internal connections are made with flame retardant cables with very low smoke emission (other types of cables on

request). On the non-pre-insulated terminals the connection point is covered with a long-life heat-shrinking sheath. The

 $auxiliary\ voltage\ are\ appropriately\ identified\ in\ compliance\ with\ current\ regulations.$ 

3-pole contactors

Capacitors

Each battery is switched on / off by a three-pole contactor (Class AC6-b) to offer high reliability. The limitation of current

Single-phase capacitors in self-healing metallized polypropylene (MKP), equipped with an anti-burst device and discharge

peaks caused by the insertion of the capacitive batteries is guaranteed by pre-charging resistors.

Fuses Each capacitors bank is protected by fuses. The protection system of both the power circuits (NH-00 curve gG fuses) and

 $the \ auxiliary \ ones \ (isolable \ fuse \ holders \ and \ 10.3x38 \ fuses) \ for essees \ the \ use \ of \ high \ breaking \ power \ fuses \ (100kA).$ 

resistance. They are impregnated in vegetable oil, PCB free. Delta connection. Type of continuous service.

rated voltage: 500 Vac (maximum voltage 550 Vac)
overvoltage: 1.1 x A (8h / 24h)

• current overload: 1.3 x ln

• capacity tolerance: -5% / + 10%

• capacity tolerance: -5% / + 10%

• losses due to dissipation: ≤0.4 W / kvar

 $\bullet$  temperature category: -25 / D

**Controller** • type of measurement: varmetric.

 $\bullet \, amperometric \, signal: \, by \, means \, of \, an \, amperometric \, transformer \, with \, secondary \, 5A, \, class \, 1 \, - \, \, 5VA \, (by \, the \, user)$ 

 $\bullet$  amperometric signal sensitivity: 2.5% for BMR series, 0.3% for HPR series

• standard capacitors on / off times: 25 "÷ 30" (others on request)

### **QUALITY AND TESTING**

Regulations Capacitors: IEC/EN 60831-1 / 2 certified by IMQ (V1927); Equipment: IEC/EN 61439-1 / 2, IEC/EN 61921.

European directives Low voltage: 2014/35/CE; Electromagnetic compatibility: 2014/30/CE.

**Testing** 100% of the automatic equipment is subject to visual inspection, insulation test: phase-phase and phase-earth,

battery efficiency and ventilation circuit control: the report is included in the documentation. The capacitors are tested

in three consecutive stages of the production process: after winding, regeneration and before labeling.



# Automatic Power Factor Correction equipment

### **CONFIGURATION**

### General notes

- For dimensions, please consult the cabinet drawings, referring to the "Type" column.
- The indication for cable entry (power supply) is as follows: ↑ from the bottom, ✓ side up, ↓ from the top
- The rated power is expressed at 415 V 50 Hz.

The choice of supply cables depends on the installation conditions, the length of the same and the ambient temperature. For a correct sizing, refer to the IEC 60364-5, CEI 64-8 and the UNEL 35024/01 standards.

### Cloud Control System (CCS)

The symbol  $\mathfrak{P}$  indicates that CCS, the remote monitoring system, is pre-installed on the P.F.C. equipment. For any specific information, and to find out the advantages of the Cloud Control System service, refer to the appropriate brochure available on www.comarcond.com or directly on request.



### Table

THD(I)max. = 35%

THD(Ic)max. = 80%

Code	Туре	Qn	Cable entry	ln				Bank	s size				Steps	Switch isolator	Controller	ccs	Weight
		(kvar)		(A)				(kv	ar)				(n)	(A)	(type)		(kg)
8681412102350	G3E	10,2	∠	14	3,4	3,4	3,4						3	40	BMR4		14
8681412159350	G3E	15,9	2	22	3,4	6,25	6,25						5	40	BMR4		15
8681412221350	G3E	22,15	</td <td>31</td> <td>3,4</td> <td>6,25</td> <td>12,5</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td>7</td> <td>80</td> <td>BMR4</td> <td></td> <td>16</td>	31	3,4	6,25	12,5						7	80	BMR4		16
8681412310350	G3E	31,25	∠	43	6,25	12,5	12,5						5	80	BMR4		18
8681412435350	G3E	43,75	∠	61	6,25	12,5	25						7	125	BMR4		22
8681412500350	G3E	50	2	70	12,5	12,5	25						4	125	BMR4		23
8681412625350	G3E	62,5	1	87	12,5	25	25						5	125	BMR4		26
8681412750350	G4E	75	2	104	12,5	12,5	25	25					6	160	BMR4		38
8681413100350	G4E	100	2	139	12,5	12,5	25	50					8	200	BMR4		43
8681413125355	G4RM	125	2	174	25	50	50						5	250	BMR4		80
8681413150355	G4RM	150	2	209	25	25	50	50					6	315	BMR4		85
8681413175355	G4RM	175	2	243	25	50	50	50					7	400	BMR4		87
8681413200355	G4RM	200	2	278	25	25	50	100					8	400	BMR4		89
8681413225355	G4RM	225	2	313	25	50	50	100					9	500	BMR4		95
8681413250355	G4RM	250	∠	348	25	50	75	100					10	500	BMR4		102
8681413300345	G6E	300	$\downarrow$	417	25	50	75	75	75				12	630	HPR6	<b>?</b>	175
8681413350345	G6E	350	$\downarrow$	487	50	75	75	75	75				9	800	HPR6	<b>₹</b>	192
8681413400345	G6E	400	$\downarrow$	556	50	50	75	75	75	75			14	800	HPR6	<b>?</b>	207
8681413450345	G6E	450	$\downarrow$	626	50	50	50	75	75	150			16	1000	HPR6	<b>?</b>	240
8681413500345	G6E	500	$\downarrow$	696	50	75	75	75	75	150			13	1000	HPR6	<b>?</b>	255
8681413525450	G8E	525	1	731	75	75	75	75	75	75	75		7	1250	HPR12	<b>?</b>	315
8681413600450	G8E	600	1	836	75	75	75	75	75	75	75	75	8	1250	HPR12	<b>?</b>	330
8681413675450	G8E	675	1	940	75	75	75	75	75	75	75	150	9	1600	HPR12	÷	350
8681413750450	G8E	750	1	1045	75	75	75	75	75	75	150	150	10	1600	HPR12	<b>?</b>	380
8681413825450	G8E (II)	825	1	1149	75	75	75	75	75	150	150	150	11	800+1000	HPR12	<b>≅</b>	510
8681413900450	G8E (II)	900	1	1254	75	75	75	75	150	150	150	150	12	1000+1000	HPR12	<u></u>	530
8681413975450	G8E (II)	975	1	1358	75	75	75	150	150	150	150	150	13	1000+1000	HPR12	<u></u>	550
8681414105450	G8E (II)	1050	<b>↑</b>	1462	75	75	150	150	150	150	150	150	14	1000+1000	HPR12	<u>@</u>	650
8681414120450	G8E (II)	1200	1	1671	75	75	150	150	150	150	150	300	16	1250+1250	HPR12	<b>®</b>	690
8681414135450	G8E (II)	1350	<b>↑</b>	1880	75	75	150	150	150	150	300	300	18	1250+1250	HPR12	<u>@</u>	730

